

Emergency Lighting Equipment Test Log Functional Testing Records

Unit Location/#	Date:												
	Duration:												
	Pass/Fail:												
	Tester:												
	Notes:												
	Duration:												
	Pass/Fail:												
	Tester:												
	Notes:												
	Duration:												
	Pass/Fail:												
	Tester:												
	Notes:												
	Duration:												
	Pass/Fail:												
	Tester:												
	Notes:												
	Duration:												
	Pass/Fail:												
	Tester:												
	Notes:												
	Duration:												
	Pass/Fail:												
	Tester:												
	Notes:												

Life Safety Code, 2012 Edition, 7.9.3 Periodic Testing of Emergency Lighting Equipment

*Testing of required emergency lighting systems shall be permitted to be conducted as follows: Functional testing shall be conducted **monthly**, with a minimum of 3 weeks and a maximum of 5 weeks between tests, for **not less than 30 seconds**. Functional testing shall be conducted **annually** for a **minimum of 1½ hours** if the emergency lighting system is battery powered.*

Written records of visual inspections and tests shall be kept by the owner for inspection by the authority having jurisdiction.